

# Certificate of Compliance

Certificate Number 20051020-E171230K  
Report Reference E171230, 2003 January 17  
Issue Date 2003 January 17

Page 1 of 3



*Issued to:* **CONTROL TECHNIQUES LTD**


*This is to certify that representative samples of* **See addendum**

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* **UL508C Power Conversion Equipment  
CSA C22.2 No.14**

*Additional Information:* **See addendum**

**Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers;  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: 

**Lilia Knauer**

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International (UK) Ltd.  
For questions in United Kingdom, you may call +44 (0) 1483302130.

Reviewed by: 

**Daniel Bejnarowicz**

UL International (U.K.) Ltd.

# Certificate of Compliance

Certificate Number 20051020-E171230K  
Report Reference E171230, 2003 January 17  
Issue Date 2003 January 17

Page 2 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

"Open" type Power Conversion Equipment - Unidrive "SP" frame size 2 series; Cat. Nos. SP2201, 2202, 2203, 2401, 2402, 2403, **may be followed by KM.**

USL, CNL - "Open" type Power Conversion Equipment - Unidrive "ES" frame size 2 series; Cat. Nos. ES2201, 2202, 2203, 2401, 2402, 2403, **may be followed by KM.**

Issued by:

**Lilia Knauer**

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International (UK) Ltd.  
For questions in United Kingdom, you may call +44 (0) 1483302130.

Reviewed by:

**Daniel Bejnarowicz**

UL International (U.K.) Ltd.

# Certificate of Compliance

Certificate Number 20051020-E171230K  
Report Reference E171230, 2003 January 17  
Issue Date 2003 January 17

Page 3 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Ratings:

Model	Input				Output				
	Volts	FLA (3ph)	Phase	Hz	Volts	FLA / Hp	Phase	Hz	
ES or SP	2201	240	18.1	3	50/60	230	15.5/5Hp	3	0-3000Hz
	2202	240	22.6	3	50/60	230	22/7.5Hp	3	0-3000Hz
	2203	240	28.3	3	50/60	230	28/10Hp	3	0-3000Hz
	2401	480	17	3	50/60	480	15.3/10Hp	3	0-3000Hz
	2402	480	21.4	3	50/60	480	21/15Hp	3	0-3000Hz
	2403	480	27.6	3	50/60	480	29/20Hp	3	0-3000Hz

Issued by:

**Lilia Knauer**

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International (UK) Ltd.  
For questions in United Kingdom, you may call +44 (0) 1483302130.

Reviewed by:

**Daniel Bejnarowicz**

UL International (U.K.) Ltd.