

# Certificate of Compliance

Certificate Number 20051020-E171230L  
Report Reference E171230, 2003 April 14  
Issue Date 2003 April 14

Page 1 of 3



*Issued to:* **CONTROL TECHNIQUES LTD**


*This is to certify that representative samples of* **See addendum**

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* **UL508C Power Conversion Equipment  
CSA C22.2 No. 14**

*Additional Information:* **See addendums**

**Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: 

**Lilia Knauer**

UL International (U.K.) Ltd.

Reviewed by: 

**Daniel Bejnarowicz**

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc./UL International (UK) Ltd.  
For questions in United Kingdom, you may call +44 (0) 1483302130.

# Certificate of Compliance

Certificate Number 20051020-E171230L  
Report Reference E171230, 2003 April 14  
Issue Date 2003 April 14

Page 2 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

"Open" type Power Conversion Equipment - Unidrive "SP" frame size 3 series; Cat. Nos. SP3201, 3202, 3401, 3402, 3403, 3501, 3502, 3503, 3504, 3505, 3506, 3507, **may be followed by KM.**

USL, CNL - "Open" type Power Conversion Equipment - Unidrive "ES" frame size 3 series; Cat. Nos. ES3201, 3202, 3401, 3402, 3403, 3501, 3502, 3503, 3504, 3505, 3506, 3507, **may be followed by KM.**

Issued by:

**Lilia Knauer**

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International (UK) Ltd.  
For questions in United Kingdom, you may call +44 (0) 1483302130.

Reviewed by:

**Daniel Bejnarowicz**

UL International (U.K.) Ltd.

# Certificate of Compliance

Certificate Number 20051020-E171230L  
Report Reference E171230, 2003 April 14  
Issue Date 2003 April 14

Page 3 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Ratings:

Model	Input					Output			
	Volts	FLA (3ph)	Phase	Hz	Volts	FLA / Hp	Phase	Hz	
SP or ES	3201	240	43.1	3	50/60	240	42/15Hp	3	0-3000Hz
	3202	240	54.3	3	50/60	240	54/20Hp	3	0-3000Hz
	3401	480	36.2	3	50/60	240	35/25Hp	3	0-3000Hz
	3402	480	42.7	3	50/60	480	43/30Hp	3	0-3000Hz
	3403	480	53.5	3	50/60	480	56/40Hp	3	0-3000Hz
	3501	575	6.7	3	50/60	575	5.4/5Hp	3	0-3000Hz
	3502	575	8.2	3	50/60	575	6.1/5Hp	3	0-3000Hz
	3503	575	11.1	3	50/60	575	8.3/7.5Hp	3	0-3000Hz
	3504	575	14.4	3	50/60	575	11/10Hp	3	0-3000Hz
	3505	575	18.1	3	50/60	575	16/15Hp	3	0-3000Hz
	3506	575	22.2	3	50/60	575	22/20Hp	3	0-3000Hz
	3507	575	26	3	50/60	575	27/25Hp	3	0-3000Hz

Issued by:

**Lilia Knauer**

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International (UK) Ltd. For questions in United Kingdom, you may call +44 (0) 1483302130.

Reviewed by:

**Daniel Bejnarowicz**

UL International (U.K.) Ltd.